



Andrew J. Spano
County Executive

Department of Environmental Facilities

Anthony M. Landi, P.E.
Commissioner

Adam Zabinski, P.E.
First Deputy Commissioner

August 29, 2006

Anthony Guccione, Jr., RLA
John Meyer Consulting
120 Bedford Road
Armonk, NY 10504

Re: JMC Project 6004
Parcel B Office Building
The Centre at Purchase
Manhattanville Road
Town of Harrison, NY

Dear Mr. Guccione:

We have received your letter dated August 28, 2006 for the proposed Office Building at Parcel B of the Centre at Purchase with an anticipated sewage flow of 6,600 GPD.

Please be advised that the Mamaroneck Trunk Sewer and the Mamaroneck Wastewater Treatment Plant have sufficient capacity to accommodate the anticipated flow to be generated by the above captioned project.

Please keep us informed of your progress and contact the undersigned at 813-5432 if you need further information.

Very truly yours,

John K. Devany
Construction Coordinator

CC: Thomas J. Lauro, P.E., Director of Operations
Jagdish Mistry, P.E., Deputy Director, Wastewater Treatment
Michael J. Facelle, Director of Maintenance